



**ACCREDITATION
DOCUMENT**

**F-06/02
Issue Date: 18/08/2020
Rev. No: 09
LAB 254**

Accreditation No: LAB 254

Awarded to

**High Voltage and Short Circuit Laboratory, NTDC, Rawat,
Islamabad, Pakistan.**

The scope of accreditation is in accordance with the standard specifications outlined in the following page(s) of this document. The accredited scope shall be visible and legible in areas such as customer service, sample-receiving section etc and shall not mislead its users.

The accreditation was first time granted on **16-02-2022** by Pakistan National Accreditation Council.

The laboratory complies with the requirements of **ISO/IEC 17025:2017**.

The accreditation requires regular surveillance, and is valid until **15-02-2028**.

The decision of accreditation made by Pakistan National Accreditation Council implies that the organization has been found to fulfill the requirements for accreditation within the scope.

The organization however, itself is responsible for the results of performed measurements/tests.

PAKISTAN NATIONAL ACCREDITATION COUNCIL

20-06-2025

Date

-SD-

Director General



**ACCREDITATION
DOCUMENT**

F-06/02
Issue Date: 18/08/2020
Rev. No: 09
LAB 254

Testing Laboratory.

Accreditation Scope of High Voltage and Short Circuit Laboratory, NTDC,
Rawat, Islamabad, Pakistan.

Permanent laboratory premises

Materials/Products tested	Testing field (e.g. environmental testing or mechanical testing)	Types of test/ Properties measured	Reference to standardized method (e.g. ISO 14577-1:2003)/ Internal method reference
High Power (HP) Section			
Distribution Transformers 3-phase (5 to 1000) kVA	Electrical Testing	Load Loss Test (Copper Losses)	IEC – 60076-1:2011 IEC – 60076-2:2011 IEC – 60076-5:2006
		No Load Loss Test (Iron Losses)	NTDC Specification DDS- 84:2020 (11/0.415 kV)
		Measurement of Winding Resistance Test	NTDC Specification DDS-71:2004
		Turn Ratio Test	KE Specification K/R&D/DT – 28 Rev (05):2018 NTDC Specification P – 41:81
Distribution Transformers 3-phase (5 to 1000) kVA	Electrical Testing	Short Circuit Test	IEC – 60076-1:2011 IEC – 60076-2:2011 IEC – 60076-5:2006 NTDC Specification DDS- 84:2020 (11/0.415 kV)
		Temperature Rise Test	NTDC Specification DDS-71:2004 KE Specification K/R&D/DT – 28 Rev (05):2018 NTDC Specification P – 41:81

20-06-2025
Date

-Sd-
Director



**ACCREDITATION
DOCUMENT**

F-06/02
Issue Date: 18/08/2020
Rev. No: 09
LAB 254

High Voltage (HV) Section

Distribution Transformers 3-phase (5 to 1500) kVA	Electrical Testing	Lightning Impulse Voltage Withstand Test	IEC-60060-1:2010 IEC-60076-1:2011 IEC 60076-3:2018 NTDC Specification DDS-84:2020
		Applied Voltage Test	
		Induced overvoltage withstand test	
15 kV Power Cable and Accessories (Termination Kits and Joints) 1. 11 kV 2. LT (415/600/1000 V)	Electrical Testing	Lightning Impulse Voltage Withstand Test	IEC 60060-1:2010 IEC 60502-2:2014 IEC 60502-4:2010 IEC 60230:2018 IEC 61442:2005 IEEE 48:2020 P-184:86 P-29:2010 DDS-41 KE Spec No. 145:2012 KE Spec No. 235, 236
		Power Frequency Dry Voltage Withstand Test	
		DC Voltage Withstand Test	
Medium Voltage Switchgear Panel (1 to 33) kV	Electrical Testing	Lightning Impulse Voltage Withstand Test	IEC 60060-1:2010 IEC 62271-1:2017
11 kV Dropout Cut Out	Electrical Testing	Lightning Impulse Voltage Withstand Test	IEC 60060-1:2010 IEC 60282-2:2008
		Power Frequency Dry Test	DDS-49:2009 KE Spec No. 176
11 kV Busbar Insulation Tubing	Electrical Testing	AC Voltage Withstand Test	IEC 60684-2:2011

20-06-2025
Date

-Sd-
Director



**ACCREDITATION
DOCUMENT**

F-06/02
Issue Date: 18/08/2020
Rev. No: 09
LAB 254

Oil Testing Section

Transformer Oil	Chemical Testing	Dielectric Strength	IEC-60156:2018
		Flash Point	ISO 2719:2016 (AMD-1:2021)
		Dielectric Dissipation Factor @ 90 °C	IEC-60247:2004
		Resistivity	IEC-60247:2004
		Water Content	IEC-60814:1997
		Color	ASTM D1500:2017

20-06-2025
Date

-Sd-
Director